



CERTIFICATE

This is to certify that

BERECO GROUP

Meet the requirements of BS6180:2011

**BARRIERS IN & ABOUT BUILDINGS
CODE OF PRACTICE**

RESULTS

Load type	Applied load (kN/m)	Pass / Fail
Horizontal uniformly distributed line load	0.36 (kN/m) 0.74 (kN/m)	Pass
Horizontal uniformly distributed load to the infill	0.5 (kN/m) 1.0 (kN/m)	Pass
Point load applied to part of the infill	0.25 (kN/m) 0.5 (kN/m)	Pass

Valid from: 18th February 2026 | Valid for 3 Years

Scope: Bereco Timber Vertical Sliding Sash Window

Test report no: 001_2023